

June 16, 2025

Chris Browning, Manager
Oklahoma City Water Utilities Trust
c/o John W. Bannen, Wastewater Quality Superintendent
420 West Main Street, Suite 500
Oklahoma City, Oklahoma 73102-4406

Re: Amendment to Add Biosolids Land Application Sites - Approved
Oklahoma City Water Utilities Trust – Chisholm Creek, Deer Creek, North-Canadian,
and South-Canadian Wastewater Treatment Facilities
Sludge Management Plan No. 3555023
Facility Nos. S-20968, S-20970, S-20580, and S-23528
OPDES Permit Nos. OK0027553, OK0027561, OK0036978, and OK0038385

Dear Mr. Browning:

On April 28, 2025, the Oklahoma Department of Environmental Quality (DEQ), Water Quality Division (WQD), received the City of Oklahoma City's request to add six (6) land application sites. On May 13, 2025, and May 23, 2025, DEQ received additional information on Chisholm Creek, Deer Creek, North-Canadian, and South-Canadian Wastewater Treatment Facilities (WWTF) sludge Toxicity Characteristic Leaching Procedure (TCLP), polychlorinated biphenyls (PCBs), percent solids, and nutrients laboratory analyses, as well as application method, vector attraction reduction method, and buffer zone for the OK-OK-41-2 land application site. Approval of the sites is granted based on the information provided.

APPROVED:

- Site OK-LI-278-1: 34.4 acres located within the NE $\frac{1}{4}$ & SE $\frac{1}{4}$ of SE $\frac{1}{4}$ Section 10, Township 12 N, Range 3 E of the Indian Meridian, Oklahoma County, Oklahoma.
- Site OK-OK-148-1: 18.9 acres located within the NE $\frac{1}{4}$ of SE $\frac{1}{4}$ Section 32, Township 13 N, Range 1 E of the Indian Meridian, Oklahoma County, Oklahoma.
- Site OK-GT-400: 137 acres located within the NE $\frac{1}{4}$ Section 14, Township 27 N, Range 7 W of the Indian Meridian, Oklahoma County, Oklahoma.
- Site OK-OK-41-2: 79 acres located within the SE $\frac{1}{4}$, SE $\frac{1}{2}$, NW $\frac{1}{4}$, NE $\frac{1}{4}$ of Section 24, Township 13 N, Range 2 W of the Indian Meridian, Oklahoma County, Oklahoma.
- Site OK-OK-149-1: 21.5 acres located within the NE $\frac{1}{4}$ & SE $\frac{1}{4}$ of NW $\frac{1}{4}$ Section 32, Township 13 N, Range 1 E of the Indian Meridian, Oklahoma County, Oklahoma.


Amendment to Add Biosolids Land Application Sites - Approved
OCWUT Wastewater Treatment Facilities
Facilities Nos. S-20968, S-20970, S-20580, and S-23528
June 16, 2025
Page 2 of 2

Site OK-LI-279: 24 acres located within the SE $\frac{1}{4}$, NE $\frac{1}{4}$ Section 35, Township 13 N,
Range 2 E of the Indian Meridian, Oklahoma County, Oklahoma.

It should be noted that DEQ regulation prohibits land application on slopes exceeding five percent (5%). Sites application approved is subject to the provisions of Oklahoma City Sludge Management Permit No. 3555023 and should be made a part of the permanent record. Any change or deviation from the permit must be approved in writing by DEQ.

If you have any questions, please contact me at 405-702-8132 or write to me at the letterhead address.

Sincerely,

A handwritten signature in blue ink that reads "Nima Sharifi". The signature is written in a cursive style with a horizontal line underneath the name.

Nima Sharifi, District Representative
Municipal Wastewater Enforcement Section
Water Quality Division
Oklahoma Department of Environmental Quality

NS/MM/lv

TWH/CG

cc: David Sauble, Treatment Supervisor, OCWUT
Stephen Henry, Regional Manager, ECLS, DEQ